

**EVALUATION OF BID
PROPOSALS**

FOR: REHABILITATE 20 INCH DIAMETER WELL AT PUMP STATION 80

Bid File No. 3361
Bid Opening: 3/17/15

BIDDERS

TOTAL NET BID AMOUNT

1. Zim Industries 4545 East Lincoln Avenue Fresno CA 93725	\$222,690.00
--	--------------

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division at the latest by Monday, April 6, 2015, 5:00 P.M.

The Engineer's Estimate for this expenditure is \$ 189,800. The contract price is 17.3 % above the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

Zim Industries was the only bid that was submitted. The vendor stated that due to the extreme demand for well drilling and rehab, it has become necessary to raise wages and purchase more equipment to facilitate the demand thus an increase above historical bids.

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment):

PS 80 is a 20 inch well that was drilled in 1970 at a depth of 430 feet. It currently produces about 400 gallons per minute with severe plugging in the perforations and an old suction screen lodged at 306 feet and assumed going to 430 feet which is the bottom of the well. By rehabilitating this well it is expected that it can be restored to a full capacity of 800 gpm supplying favorable water pressure in zone 14 which is near Fresno Yosemite International Airport and towards Southeast Fresno.

