Page 1

EVALUATION OF BID PROPOSALS

FOR: REHABILITATE 16 INCH DIAMETER WELL AT PUMP STATION 244 FURNISH AND INSTALL 14 INCH OD FUL FLOW LINER

Bid File No. 3360 Bid Opening: 3/3/15

BIDDERS

TOTAL NET BID AMOUNT

 Zim Industries, Inc.
 4545 E. Lincoln Avenue Fresno CA 93725 \$237,680.00

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division <u>at the latest by Monday, March 23, 2015, 5:00 P.M.</u>

The Engineer's Estimate for this expenditure is \$250,000. The contract price is 4.9% below the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment): This 16" diameter well was drilled in 1964, and is 340 deep. This well produces over 1,000 gallons per minute with an excess sand content due to the old style vertical slot casing, corrosion of the casing, and lack of gravel pack. By adding an inside liner with Ful-Flo stainless steel perforations, we will be able to maintain the current rate of 1,000 gallons per minute with no sand production. In addition to rehabilitating this well, we can remove the surge tank from this site that has been accumulating the sand production in the past, and creating additional maintenance to clean the sand out of this tank. Due to the wells location on Barstow and Del Mar, it is a critical pressure sustainer during peak months of production, and convenient for maintenance because it is neighboring a FMFCD basin when flushing.

EVALUATION OF BID PROPOSALS

FOR: REHABILITATE 16 INCH DIAMETER WELL AT PUMP STATION 244 FURNISH AND INSTALL 14 INCH OD FUL FLOW LINER

Bid File No. 3360 Bid Opening: 3/3/15

	Bid Opening. Grof to
DEPARTM	ENT CONCLUSIONS AND RECOMMENDATION:
[<u>X</u>]	Award a contract in the amount of \$ 237,680.00 to Zim Industries, Inc. as the lowest responsive and responsible bidder.
	Remarks:
	[] Reject all bids. Reason:
Depa	artment Head Approval
Hm	Fackel
Title	Water Systems Manager
Date	3-5-15
	Approve Dept. Recommendation [
[]	Disapprove [] Disapprove
[]	See Attachment
FINA	NCE DEPARTMENT CITY MANAGER
	my A Gene Chil 3/6/15
Purč	hasing Manager Date City Manager or Designee / Date
	Mobreel hung 3/10/15
rinai	nce Director Date

FISCAL IMPACT STATEMENT

PROGRAM: REHAB 16 INCH DIAMETER WELL AT PUMP STATION 244 FURNISH AND INSTALL 14 INCH OD FUL-FLO LINER

RECOMMENDATION	TOTAL OR CURRENT	ANNUALIZED COST
Direct Cost	\$237,700	\$237,700
Indirect Cost	\$2,500	\$2,500
TOTAL COST	\$240,000	\$240,000
Additional Revenue or Savings Generated	0	0
Net City Cost	\$240,000	\$240,000
Amount Budgeted (If none budgeted, identify source)	\$256,000	\$256,000