

**EVALUATION OF BID  
PROPOSALS**

Page 1

FOR: Rehabilitate 20 Inch Diameter Well at Pump Station 62A

Bid File No.3458  
Bid Opening:5/17/16

---

<b><u>BIDDERS</u></b>	<b><u>TOTAL NET BID AMOUNT</u></b>
1. Zim Industries 4545 E. Lincoln Ave. Fresno, CA 93725	\$216,430.00
2. Hydro Resources – West, Inc. 800 E Ash Ave Shafter, CA 93263	\$217,310.00*
3. Cascade Drilling, L.P. 3000 Duluth Street West Sacramento, CA 95691	\$289,790.00**

**NOTE:**

\* Non-responsive: no statement of qualifications, no subcontractor detail page

\*\*No subcontractor detail page

---

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division at the latest by Monday, June 13, 2016, 5:00 P.M.

The Engineer's Estimate for this expenditure is \$350,000. The contract price is 38% below the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

**BACKGROUND OF PROJECT** (To be completed by Evaluating Department/Division. Explain need for project/equipment): Pump Station 62A has decreased in production over the years and a well video revealed that the casing is severely plugged. We have installed a VFD and have extended the pump bowls 40 feet to prevent breaking suction due to severe drawdown from plugged well casing perforations. This well is worth 3,600 GPM when cleaned properly.

**EVALUATION OF BID  
PROPOSALS**

Page 2

FOR: Rehabilitate 20 Inch Diameter Well at Pump Station 62A

Bid File No.3458  
Bid Opening:5/17/16

---

**DEPARTMENT CONCLUSIONS AND RECOMMENDATION:**

Award a contract in the amount of \$ 216,430 to Zim Industries as the lowest responsive and responsible bidder.

Remarks:

Reject all bids. Reason:

**EVALUATION OF BID PROPOSALS**

FOR: Rehabilitate 20 Inch Diameter Well at Pump Station 62A

Bid File No.3458  
Bid Opening:5/17/16

Department Head Approval

HM [Signature]

Title DIRECTOR OF PUBLIC UTILITIES

Date 5-19-16

- Approve Dept. Recommendation     Approve Finance/Purchasing Recommendation  
 Disapprove     Disapprove  
 See Attachment

FINANCE DEPARTMENT

CITY MANAGER

[Signature]  
Purchasing Manager

5/20/16  
Date

[Signature] 5/20/16  
City Manager or Designee    Date

[Signature] 5/20/16  
Finance Director    Date

## FISCAL IMPACT STATEMENT

PROGRAM: Rehabilitate 20 Inch Diameter Well at Pump Station 62A  
(WC00017 Well Rehabilitation)

<u>RECOMMENDATION</u>	<u>TOTAL OR CURRENT</u>	<u>ANNUALIZED COST</u>
Direct Cost	<u>\$216,430</u>	<u>\$216,430</u>
Indirect Cost	<u>\$20,000</u>	<u>\$20,000</u>
TOTAL COST	<u>\$236,430</u>	<u>\$236,430</u>
Additional Revenue or Savings Generated	<u>0</u>	<u>0</u>
Net City Cost	<u>\$236,430</u>	<u>\$236,430</u>
Amount Budgeted (If none budgeted, identify source)	<u>\$350,000</u>	<u>\$350,000</u>
Indirect Cost:		
Project Mgmt	<u>\$5,000</u>	
Construction Mgmt	<u>\$10,000</u>	
Construction	<u>\$5,000</u>	
Total	<u>\$20,000</u>	