

**EVALUATION OF BID
PROPOSALS**

FOR: 2-WATER BOOSTER PUMP STATION REDUNDANCY IMPROVEMENT PROJECT

Bid File No. 12500873
Bid Opening: 12/17/2024

BIDDERS

TOTAL NET BID AMOUNT

1. Alliance Construction Solutions, Inc 36376 Kenneth Ave Madera, CA 93636	\$1,125,500.00
2. TSI Engineering, Inc 4600 Roseville Rd Ste 140 North Highlands, CA 95660	\$1,193,786.00
3. Mehta Mechanical Company, Inc 5901 Fresca Dr La Palma, CA 90623	\$1,244,300.00
4. Walsh Montgomery Construction, Inc 1477 Menlo Ave Clovis, CA 93611	\$1,244,345.00
5. Canyon Springs Enterprises 27476 Via Industria Temecula, CA 92590	\$1,381,720.00
6. HPS Mechanical, Inc 3100 E. Belle Terrace Bakersfield, CA 93307	\$1,430,400.00

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division at the latest by Monday, January 13, 2025 5:00 P.M.

The Engineer's Estimate for this expenditure is \$980,000.00. The contract price is 14.8% above the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

Upon review of the submitted bid proposals, the storage tank and pipe material costs were consistently higher than what was estimated, which led to the overage. The increase in these material costs was consistent across the six responsive bid proposals received.

**EVALUATION OF BID
PROPOSALS**

FOR: 2-WATER BOOSTER PUMP STATION REDUNDANCY IMPROVEMENT PROJECT

Bid File No. 12500873

Bid Opening: 12/17/2024

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment):

The 2-Water Booster Pump Station is a critical system at the Fresno-Clovis Regional Wastewater Reclamation Facility (RWRF) as it provides flush water to the mechanical pumps, cooling water for the raw sewage pumps, provides water to the heat exchangers for their heating and cooling process, and is a large source of cleaning water. This project includes installation of a second storage tank, and the addition and reconfiguration of valves and piping to allow for isolation of the system elements. These improvements will provide redundancy to protect critical assets at the RWRF, and allow staff to perform more regular routine service and maintenance of the pump station components, thereby extending their useful life.

EVALUATION OF BID PROPOSALS

FOR: 2-WATER BOOSTER PUMP STATION REDUNDANCY IMPROVEMENT PROJECT

Bid File No. 12500873
Bid Opening: 12/17/2024

DEPARTMENT CONCLUSIONS AND RECOMMENDATION:

Award a contract in the amount of \$1,125,500.00 to Alliance Construction Solutions, Inc. as the lowest responsive and responsible bidder.

Remarks:

Reject all bids. Reason:

Department Head Approval



Brock D. Buche, PE, PLS
Director of Public Utilities

Date 1/10/25

Approve Dept. Recommendation

Disapprove

See Attachment

Approve GSD/Purchasing Recommendation

Disapprove

GENERAL SERVICES DEPARTMENT

CITY MANAGER



Purchasing Manager

01/14/2025


Date



City Manager or Designee

Date

DocuSigned by:



1/14/2025

General Services Director

Date

FISCAL IMPACT STATEMENT

PROGRAM: 2-Water Booster Pump Station Redundancy Improvement Project
 Sewer Enterprise Fund
 Proj. ID: TC00180, Res Type: WW001 Fund: 40501, Org: 414501

<u>RECOMMENDATION</u>	<u>TOTAL OR CURRENT</u>	<u>ANNUALIZED COST</u>
Direct Cost	<u>\$1,125,500.00</u>	_____
Indirect Cost	<u>\$48,000.00</u>	_____
TOTAL COST	<u>\$1,173,500.00</u>	_____
Additional Revenue or Savings Generated	<u>\$0.00</u>	_____
Net City Cost	<u>\$1,173,500.00</u>	_____
Amount Budgeted (If none budgeted, identify source)	<u>\$1,200,000.00</u>	_____
<u>*Indirect Costs</u>		
Design Development	<u>\$5,000.00</u>	
Construction Management	<u>\$30,000.00</u>	
Administration	<u>\$3,000.00</u>	
Other	<u>\$10,000.00</u>	