

REGULAR MEETING

June 29, 2023

FRESNO CITY COUNCIL



Supplemental Packet

ITEM(S)

1-S File ID 23-1002 - Actions pertaining to the cleaning of Digester #1 and cleaning and rehabilitation of Digester #12 at the Fresno-Clovis Regional Wastewater Reclamation Facility (Bid File 12302079) (Council District 3):

Supplement Content: Environmental Assessment

Item(s)

Supplemental Information:

Any agenda related public documents received and distributed to a majority of the City Council after the Agenda Packet is printed are included in Supplemental Packets. Supplemental Packets are produced as needed. The Supplemental Packet is available for public inspection in the City Clerk's Office, 2600 Fresno Street, during normal business hours (main location pursuant to the Brown Act, G.C. 54957.5(2)). In addition, Supplemental Packets are available for public review at the City Council meeting in the City Council Chambers, 2600 Fresno Street. Supplemental Packets are also available on-line on the City Clerk's website.

Americans with Disabilities Act (ADA):

The meeting room is accessible to the physically disabled, and the services of a translator can be made available. Requests for additional accommodations for the disabled, sign language interpreters, assistive listening devices, or translators should be made one week prior to the meeting. Please call City Clerk's Office at 621-7650. Please keep the doorways, aisles and wheelchair seating areas open and accessible. If you need assistance with seating because of a disability, please see Security.

**CITY OF FRESNO
CATEGORICAL EXEMPTION
ENVIRONMENTAL ASSESSMENT**

THE PROJECT DESCRIBED HEREIN IS DETERMINED TO BE CATEGORICALLY
EXEMPT FROM THE PREPARATION OF ENVIRONMENTAL DOCUMENTS
PURSUANT TO ARTICLE 19 OF THE STATE CEQA GUIDELINES.

CONTACT: Sarah Aguila
City of Fresno – Department of Public Utilities
1626 E Street
Fresno, CA 93706
Phone: 559-621-1615
Email: sarah.aguila@Fresno.gov

PROJECT TITLE: Cleaning of Digester #1 and Cleaning and
Rehabilitation of Digester #12 at the Fresno/Clovis
Regional Wastewater Reclamation Facility

PROJECT LOCATIONS: 5607 W. Jensen Avenue

PROJECT DESCRIPTION: The purpose of the project is to clean and rehabilitate two existing digesters at the Regional Wastewater Reclamation Facility, which includes cleaning, dewatering, coating, and sealing of the interior surfaces of the digesters with an elastomeric polyurethane material, as well as all associated facilities, appurtenances, and incidentals.

The Project is exempt under Section 15301(d)/Class 1 of the California Environmental Quality Act (CEQA) Guidelines.

Class 1 consists of the operation, repair, maintenance, permitting, leasing, licensing, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of existing or former use. The proposed project is consistent with the Class 1 exemption. The Project entails the restoration of existing utility facilities. Following routine maintenance and inspections of the Digesters #1 and #12, seepage stains and visible concrete surface cracks were discovered. This Project includes the routine cleaning and dewatering of the digesters, and removal and replacement of the existing interior coating, which has exceeded its life expectancy. The Project is necessary to correct deficiencies within the interior structure of the digesters in order to meet public health standards for a wastewater facility, as is consistent with a Section 15301/Class 1 exemption. The proposed cleaning and restoration will not result in any expansion of the existing use of the digesters.

None of the exceptions to Categorical Exemptions set forth in the CEQA Guidelines, Section 15300.2, apply:

- | | |
|----------------------------------|---|
| (a) Location | The Project is not located in a sensitive environment or an environmental resource of hazardous or critical concern as designated by federal, state, or local agencies. |
| (b) Cumulative Impact | The Project will not have a cumulative negative impact over time that is significant. A digester is rehabilitated once every 7 or more years and the impacts are beneficial to the operation of the wastewater facility. |
| (c) Significant Effect | The Project will not have a significant effect on the environment due to unusual circumstances. The digester rehabilitations are routine maintenance following industry standards. |
| (d) Scenic Highways | The Project will not result in damage to scenic resources, including but not limited to, trees, historic buildings, rock outcroppings, or similar resources, within a highway officially designated as a state scenic highway. The Project is not located near scenic highways. |
| (e) Hazardous Waste Sites | The Project is not located on a hazardous waste site which is included on any list compiled pursuant to Section 65962.5 of the Government Code. |
| (f) Historical Resources | The Project will not cause a substantial adverse change in the significance of a historical resource. The Project is limited to rehabilitation digesters at the Fresno/Clovis Regional Wastewater Reclamation Facility, which are not historical resources. |

Furthermore, the proposed project is not expected to have a significant effect on the environment. Accordingly, a categorical exemption, as noted above, has been prepared for the project.

Date: May, 17, 2023

Prepared by: Sarah Aguila