

**EVALUATION OF BID
PROPOSALS**

FOR: MILBURN AND HERNDON JUNCTION STRUCTURE REPAIRS

Bid File No. 3642
Bid Opening:
2/26/2019

BIDDERS

TOTAL NET BID AMOUNT

1. Floyd Johnston Construction Co., Inc.
2301 Herndon Ave
Clovis CA 93611

\$268,213.00 ^{MP}

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Unit at the latest by Monday, March 25, 2019 by 5:00 P.M.

The Engineer's Estimate for this expenditure is \$236,000. The contract price is 13.65% above the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

During the bid period, changes were made to the project by addendum. Some items that were originally identified to be reconstructed were changed to be "replaced". The addendum was issued due to the fact that the severely deteriorated state of the original parts, due to hydrogen sulfide gasses, made finding replacement parts impossible. Therefore it was decided that the entire mechanisms should be replaced. These changes significantly increased the overall cost of the project repairs.

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment):

During routine inspections, the Wastewater Collections System Division discovered the access door raised. Upon further inspection, the access door was found to be completely deteriorated and unable to close and the mechanical portions of the structure eaten away by the hydrogen sulfide gasses. The Department of Public Utilities recommends rehabilitation of the structure such as reconstruction of the access door and frame, reconstruction of the gate operator assembly, and replacement of the frame and cover. The repairs will restore the structures stability and allow the junction structure to operate at its intended function.

EVALUATION OF BID
PROPOSALS

FOR: MILBURN AND HERNDON JUNCTION STRUCTURE REPAIRS

Bid File No. 3642
Bid Opening:
2/26/2019

DEPARTMENT CONCLUSIONS AND RECOMMENDATION:

Award a contract in the amount of \$268,213 to Floyd Johnston Construction Co., Inc. as the lowest responsive and responsible bidder.

Remarks:

Reject all bids. Reason:

Department Head Approval



Dejan Pavic

Title Supervising Professional Engineer

Date 02/28/2019

Approve Dept. Recommendation Approve Finance/Purchasing Recommendation

Disapprove

Disapprove

See Attachment

FINANCE DEPARTMENT

CITY MANAGER



Purchasing Manager

02/28/2019

Date



City Manager or Designee

3/1/19

Date



Finance Director

Date

FISCAL IMPACT STATEMENT

PROGRAM: Sewer Enterprise Fund
Proj. ID: RC00174, Res Type: J5725, Fund: 40501, Org: 413501

<u>RECOMMENDATION</u>	<u>TOTAL OR CURRENT</u>	<u>ANNUALIZED COST</u>
Direct Cost	<u>\$268,213.00</u>	_____
Indirect Cost	<u>\$25,000.00</u>	_____
TOTAL COST	<u>\$293,213.00</u>	_____
Additional Revenue or Savings Generated	<u>\$0.00</u>	_____
Net City Cost	<u>\$293,213.00</u>	_____
Amount Budgeted (If none budgeted, identify source)	<u>\$300,500.00</u>	_____
<u>*Indirect Costs</u>		
Inspection	<u>\$20,000.00</u>	
Administration	<u>\$1500.00</u>	
Contract Compliance	<u>\$1500.00</u>	
Other	<u>\$2000.00</u>	