

**EVALUATION OF BID
PROPOSALS**

FOR: Cleaning of Digester #2 and Cleaning/Rehabilitation of Digester #9 at the Fresno-Clovis Regional Wastewater Reclamation Facility

Bid File No. 12401763
Bid Opening: 04/23/2024

<u>BIDDERS</u>	<u>TOTAL NET BID AMOUNT</u>
1. F.D. Thomas, Inc. 217 Bateman Drive Central Point, OR 97502	\$1,135,915.00
2. Euro Style Management 1401 Main Avenue Sacramento, CA 95838	\$1,475,000.00 *Non-responsive
3. Unified Field Services Corporation 6906 Downing Avenue Bakersfield, CA 93308	\$1,730,860.00

*The bidder failed to submit required documentation and is therefore deemed non-responsive.

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division at the latest by Monday, May 20, 2024, 5:00 P.M.

The Engineer's Estimate for this expenditure is \$1,200,000.00. The contract price is 5.3% below the Engineer's Estimate/Budget Allocation. If the overage is greater than 10% or only one bid was received, give explanation:

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment):

The Facility treats approximately 68 million gallons per day of wastewater conveyed from the Fresno-Clovis area. The Facility operates 13 mesophilic anaerobic digesters to eliminate pathogens and volatile organic compounds from the biosolids generated throughout the treatment process. The digesters range in size from 860,000 to 1,870,000 gallons. Over the period of approximately seven years, these digesters accumulate undesirable debris associated with the treatment process (i.e., sand, plastics, hair, etc.).

Following routine maintenance and inspections of Digesters #2 and #9, seepage stains and visible concrete surface cracks were discovered. This Project includes the routine cleaning and dewatering of both digesters, and removal and replacement of the existing interior coating in Digester #9, which has exceeded its life expectancy.

EVALUATION OF BID
PROPOSALS

FOR: Cleaning of Digester #2 and Cleaning/Rehabilitation of Digester #9 at the Fresno-Clovis Regional Wastewater Reclamation Facility

Bid File No. 12401763
Bid Opening: 04/23/2024

DEPARTMENT CONCLUSIONS AND RECOMMENDATION:

Award a contract in the amount of \$1,135,915.00 to F.D. Thomas as the lowest responsive and responsible bidder.

Remarks:

Reject all bids.

Reason:

Department Head Approval



Brock D. Buche, PE, PLS
Director of Public Utilities

Date 5/22/24

Approve Dept. Recommendation

Approve GSD/Purchasing Recommendation

Disapprove

Disapprove

See Attachment

GENERAL SERVICES DEPARTMENT

CITY MANAGER


Purchasing Manager 05/24/2024
Date


City Manager or Designee 6/5/24
Date

DocuSigned by:

General Services Director 6/4/2024
Date

FISCAL IMPACT STATEMENT

PROGRAM: Sewer Enterprise Fund
Proj. ID: TC00178, Res Type: SH021/SH022 Fund: 40501, Org: 414501

<u>RECOMMENDATION</u>	<u>TOTAL OR CURRENT</u>	<u>ANNUALIZED COST</u>
Direct Cost	<u>\$1,135,915.00</u>	_____
Indirect Cost	<u>\$115,000.00</u>	_____
TOTAL COST	<u>\$1,250,915.00</u>	_____
Additional Revenue or Savings Generated	<u>\$0.00</u>	_____
Net City Cost	<u>\$1,250,915.00</u>	_____
Amount Budgeted (If none budgeted, identify source)	<u>\$2,400,000.00</u>	_____
<u>*Indirect Costs</u>		
Design Development	<u>\$5,000.00</u>	
Construction Management	<u>\$50,000.00</u>	
Administration	<u>\$10,000.00</u>	
Other	<u>\$50,000.00</u>	