

**EVALUATION OF BID
PROPOSALS**

FOR: Northeast Surface Water Treatment Facility (NESWTF) Sodium Hypochlorite Tank Replacement

Bid File No. 12400125
Bid Opening: 09/26/2023

<u>BIDDERS</u>	<u>TOTAL NET BID AMOUNT</u>
1. Harrington Process Solutions 5405 E. Home Ave., Suite 101 Fresno, CA 93727	\$357,823.06 *Non-Responsive
2. Liberty Chemical Equipment & Supply Inc. PO Box 778 Dinuba, CA 93618	\$445,335.00
3. MISCOWater 5976 W. Las Positas Blvd., #226 Pleasanton, CA 94588	\$464,662.96

*Bidder failed to submit required documents.

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division at the latest by Monday, January 29, 2024 5:00 P.M.

The Engineer's Estimate for this expenditure is \$410,000.00. The contract price is 8.6% above the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

N/A

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment):

The NESWTF has been in service since July 2004. Over the last several years, both existing fiber reinforced plastic (FRP) sodium hypochlorite tanks at the NESWTF have shown degradation issues resulting in increased frequency of repairs and maintenance. The sodium hypochlorite leaking from the aged tanks, due to its corrosive nature, caused damage to the supporting concrete pedestals including portions of the adjacent slab areas within the Chemical Storage Building. The scope of this Project is only for the procurement of new FRP tanks with long lead times. Repairs of the supporting concrete pedestals and installation of the tanks is to occur under a separate project.

EVALUATION OF BID
PROPOSALS

FOR: Northeast Surface Water Treatment Facility (NESWTF) Sodium Hypochlorite Tank Replacement

Bid File No. 12400125
Bid Opening: 09/26/2023

DEPARTMENT CONCLUSIONS AND RECOMMENDATION:

Award a contract in the amount of \$ 445,335.00 to Liberty Chemical Equipment & Supply, Inc., as the lowest responsive and responsible bidder.

Remarks:

Reject all bids. Reason:

Department Head Approval



Brock D. Buche
Title: Director of Public Utilities

Date 1/26/24

Approve Dept. Recommendation

Approve GSD/Purchasing Recommendation

Disapprove

Disapprove

See Attachment

GENERAL SERVICES DEPARTMENT

CITY MANAGER


Purchasing Manager 02/05/2024
Date


City Manager or Designee Date

DocuSigned by:

Brian Barr 2/5/2024
Date
99B07275D7AD479...
General Services Director

FISCAL IMPACT STATEMENT

PROGRAM: Northeast Surface Water Treatment Facility (NESWTF) Sodium
Hypochlorite Tank Replacement
WC00021 12400125

<u>RECOMMENDATION</u>	<u>TOTAL OR CURRENT</u>	<u>ANNUALIZED COST</u>
Direct Cost	<u>\$445,335.00</u>	
Indirect Cost	<u>\$ 5,000.00</u>	
TOTAL COST	<u>\$450,335.00</u>	
Additional Revenue or Savings Generated	<u>0.00</u>	
Net City Cost	<u>\$450,335.00</u>	
Amount Budgeted (If none budgeted, identify source)	<u>\$540,000.00</u>	

***Indirect Costs**

Project Administration	\$ <u>5,000.00</u>
Total Indirect Costs	\$ 5,000.00