

EVALUATION OF BID
PROPOSALS

FOR: SEWER REMOVAL AND REPLACEMENT ON IOWA AND EIGHTH STREET

Bid File No. 3506
Bid Opening: January 24, 2017

<u>BIDDERS</u>	<u>TOTAL NET BID AMOUNT</u>
1. Bill Nelson GEC, Inc. 7600 N Ingram Avenue Fresno CA 93711	\$340,925.00
2. Dawson-Mauldin Construction, Inc. 1071 E Nebraska Selma CA93662	\$356,716.46
3. Todd Companies 1701 N Clancy Court Visalia CA 93290	\$387,499.50
4. Ferreira Coastal Construction Co., Inc. 8413 Jackson Road Sacramento CA 95826	\$413,989.50
5. Floyd Johnston Construction Co., Inc. 2301 Herndon Clovis CA 93611	\$511,600.00
6. Caggiano General Engineering, Inc. 3941 Park Drive, Suite 20-347 El Dorado Hills CA 95762	\$562,538.73

Each bidder has agreed to allow the City sixty-four (64) days from date bids are opened to accept or reject their bid proposal. Purchasing requests that you complete the following sections and return this bid evaluation to the Purchasing Division at the latest by Monday, February 13, 2017, 5:00 P.M.

The Engineer's Estimate for this expenditure is \$350,000. The contract price is 2.6% below the Engineer's Estimate. If the overage is greater than 10% or only one bid was received, give explanation:

EVALUATION OF BID
PROPOSALS

Page 2

FOR: SEWER REMOVAL AND REPLACEMENT ON IOWA AND EIGHTH STREET

Bid File No. 3506

Bid Opening: January 24, 2017

BACKGROUND OF PROJECT (To be completed by Evaluating Department/Division. Explain need for project/equipment):

As per the Collection System Master Plan (CSMP), the Collection System Maintenance work group performs inspections of the sewer systems within the City of Fresno. The goals of these inspections are to evaluate the structural integrity and capacity of all sewer pipes within the City of Fresno. These investigations are performed using Closed Circuit Television (CCTV). During routine inspection of the sewers in May of 2016, areas within southeast Fresno were identified that required rehabilitation or replacement. This sewer line in particular was showing significant signs of structural deficiencies in some areas the pipe had completely failed with soil visible. A pipe failure such as this one has the potential of developing sink holes and even traffic accidents within the intersection. Replacement of the existing sewer line was found to be the best option after evaluation of all applicable remediation options.

EVALUATION OF BID
PROPOSALS

FOR: SEWER REMOVAL AND REPLACEMENT ON IOWA AND EIGHTH STREET

Bid File No. 3506
Bid Opening: January 24, 2017

DEPARTMENT CONCLUSIONS AND RECOMMENDATION:

Award a contract in the amount of \$ 340,925 to Bill Nelson General Engineering Construction Inc. as the lowest responsive and responsible bidder.

Remarks:

Reject all bids. Reason:

Department Head Approval



Title

Director


Date

1-30-17

- Approve Dept. Recommendation Approve Finance/Purchasing Recommendation
 Disapprove Disapprove
 See Attachment


FINANCE DEPARTMENT

CITY MANAGER


Purchasing Manager

1-31-17

Date


City Manager or Designee

2/3/17

Date


Finance Director

1/31/17

Date

FISCAL IMPACT STATEMENT

PROGRAM:

<u>RECOMMENDATION</u>	<u>TOTAL OR CURRENT</u>	<u>ANNUALIZED COST</u>
Direct Cost	<u>\$340,925</u>	<u> </u>
Indirect Cost	<u>\$24,000</u>	<u> </u>
TOTAL COST	<u>\$364,925</u>	<u> </u>
Additional Revenue or Savings Generated	<u>\$0</u>	<u> </u>
Net City Cost	<u>\$364,925</u>	<u> </u>
Amount Budgeted (If none budgeted, identify source)	<u>\$500,000</u>	<u> </u>

<u>*Indirect Costs</u>	
Inspection	<u>\$15,000.00</u>
Administration	<u>\$3,500.00</u>
Contract Compliance	<u>\$3,500.00</u>
Other	<u>\$2,000.00</u>

Funds for the project are budgeted in the FY16 Sewer Enterprise Fund No. 40501.