

## Exhibit H



**SUBJECT:** Conditions of Approval for **P23-01190**

**DATE:** 8/31/2023

**TO:** George, Planner III  
Planning and Development Department

**FROM:** Rogelio Ruiz, Engineer I  
Public Works Department, Traffic Planning Section

**ADDRESS:** 1911 East Copper River Drive

**APN:** 579-220-49s, 33s, 71s

**ATTENTION:**

**Provide corrections as noted on Exhibit "A".**

**Prior to resubmitting the corrected exhibit, provide the following information and conditions of approval on the site plan:**

**A. GENERAL REQUIREMENTS**

1. **Required Notes:** Revise General Notes to include the required Public Works Department notes.
  - a. Any survey monuments within the area of construction shall be preserved or reset by a person licensed to practice land surveying in the State of California.
  - b. Repair all damaged and/or off-grade concrete street improvements as determined by the Construction Management Engineer, prior to occupancy.
  - c. Two working days before commencing excavation operations within the street right-of way and/or utility easements, all existing underground facilities shall have been located by UNDERGROUND SERVICES ALERT (USA). CALL 1-800-642-2444
  - d. The performance of any work within the public street right-of-way requires a street work permit prior to commencement of work. All required street improvements must be completed and accepted by the City prior to occupancy. <https://www.fresno.gov/publicworks/traffic-engineering/#tab-6>
  - e. Deeds are required to provide easements to the city for required public improvements. They shall be prepared by the owner / developer's engineer. Executed copies shall be submitted to the city with verification of ownership prior to the issuance of building permits.
  - f. All existing driveway approaches which no longer provide access to approved vehicle parking areas shall be removed unless otherwise approved by the City Engineer. Such areas shall be reconstructed with curb, gutter,

and sidewalk to match existing adjacent street improvements. This work shall be completed and accepted before a Permit of Occupancy is issued or the building is occupied per FMC 13-211.

- g. Underground all existing overhead utilities within the limits of this application as per Fresno Municipal Code Section 15-2017 and Public Works Policy No. 260.01.
- h. Submit street construction plans to the Public Works Department.
- i. Provide a 4' minimum path of travel along the public sidewalk directly in front of property, to meet current accessibility regulations. A pedestrian easement may be required if requirements are not met.
- j. Contact the Public Works Department, Traffic Engineering at 559-621-8800, 10 working days prior to any offsite concrete construction.
- k. All existing sidewalks in excess of 2% maximum cross slope must be brought into compliance prior to acceptance by Public Works.
- l. All development shall take place in accordance with all city, county, state, federal, railroad laws and regulations.

## **B. OFFSITE INFORMATION:**

1. **Public Street Improvements:**
  - a. **Street-type approaches:**
2. **Accessibility:** Identify and dimension the required 4' minimum path of travel along the public sidewalk adjacent to the property. Provide pinch point dimensions. A pedestrian easement may be required if Title 24 requirements cannot be met.

## **C. ONSITE INFORMATION:**

1. **State standard "STOP":** Identify and install **30"** state standard "STOP" signs at the locations shown. A "right turn only" sign is also required; install a **30" x 36"** state standard sign immediately below the stop sign on the same post. Signs shall be mounted on a **2"** galvanized post with the bottom of the lowest sign **7'** above ground, located behind curb and immediately behind a major street sidewalk.
2. **Gates:**

**Multi-Family:** Provide a minimum of 100' from the proposed gate to the back of walk/right-of-way/pedestrian easement, for vehicle stacking at the main gate. – **Or-** If multiple gates are provided, a total of 50' of stacking can be split between the additional gates. If not existing, redesign the main entrance to provide for an onsite turn around. Where the entry is divided, each side shall provide for a minimum opening of 16' each. Where it is not divided, the gate shall be a minimum of 20' wide.

## PUBLIC IMPROVEMENT REQUIREMENTS

The following requirements are based on city records and the accuracy of the existing and proposed on-site and off-site conditions depicted on the exhibits submitted. Requirements not addressed due to omission or misrepresentation of information, on which this review process is dependent, will be imposed whenever such conditions are disclosed. Construct additional offsite improvements, including but not limited to, concrete curb, gutter, sidewalk, approaches, ramps, pavement, utility relocations, etc. in accordance with *City of Fresno's Public Works Standards, Specifications*, and the approved street plans.

Repair all damaged and/or off grade off-site concrete street improvements as determined by the City of Fresno Public Works Department, Construction Management Division, (559) 621-5600. Pedestrian paths of travel must also meet current accessibility regulations.

All existing sidewalks and trails in excess of 2% maximum cross slope must be brought into compliance **prior** to acceptance by Public Works.

### **Copper River Avenue: 2-Lane Collector**

(Provide the following as notes on the site plan.)

1. Construction Requirements:
  - a. Construct a driveway approach to *Public Works Standards P-2*, and **P-6**, as approved on the site plan.
  - b. The proposed street type approaches shown as **P-76**, **P-77**, this is a tentative approval until such time that a qualified Civil Engineer prepares street plans that provide the sufficient cross drainage approved by the City Engineer in accordance with *Public Works Standard P-10*. If grades are not sufficient, construct to *Public Works Standards P-2* and **P-6**.
  - c. Provide a **12'** visibility triangle at all driveways, per Fresno Municipal Code (FMC) 15-2018B.

### **Maple Avenue: 2-Lane Collector**

(Provide the following as notes on the site plan.)

Public Improvement Plans are required and shall be approved by the City Engineer. Contact Scott Tyler at (559) 621-8654 or at [Scott.Tyler@fresno.gov](mailto:Scott.Tyler@fresno.gov) and submit Public Improvement Plans for all required work, in a single package, to Engineering Services Division. Dedications shall be sufficient to accommodate additional paving and any other grading or transitions as necessary based on a **45** MPH design speed for Collectors and **55** MPH for Arterials. Utility poles, streetlights, signals, etc. shall be relocated as determined by the City Engineer. The performance of any work within the public right of way and/or easements (including street, bike, pedestrian, landscape, and utility easements) requires a **Street Work Permit prior** to commencement of work. Contact Public Works Department at (559) 621-8800, 10 working days prior to construction of any improvements in the public right-of-way and/or easements. All improvements shall be

constructed in accordance with the City of Fresno, *Public Works Department Standard Drawings and Specifications*. Traffic Control Plans shall be required to ensure the sidewalk, or an approved accessible path remains open during construction. Contact Melessa Avakian at (559) 621-8812 or at [Melessa.Avakian@fresno.gov](mailto:Melessa.Avakian@fresno.gov) and submit Traffic Control Plans to the Traffic Operations and Planning Division. All work shall be reviewed, approved, completed, and accepted **prior** to obtaining a certificate of occupancy.

Two working days before commencing excavation operations within the street right of way and/or utility easements, all existing underground facilities shall have been located by Underground Services Alert (USA) Call 811.

Any survey monuments within the area of construction shall be preserved or reset by a person licensed to practice Land Surveying in the State of California.

## **PRIVATE IMPROVEMENT REQUIREMENTS**

### **Off-Street Parking Facilities and Geometrics:**

Contact the Planning and Development Department for review and approval of onsite parking. The parking lot is required to meet the *City of Fresno's Parking Manual, Public Works Standards (P-21, P-22, and P-23) and Specifications*. Parking must also comply with the *California Building Code's* accessibility requirements and the Fire and Solid Waste Department's minimum turning templates.

### **Irrigation / Canal Requirements:**

**Traffic Signal Mitigation Impact (TSMI) Fee:** This project shall pay all applicable TSMI Fees **at the time of building permit**. Contact the Public Works Department, Frank Saburit at (559)621-8797. The fees are based on the Master fee schedule.

**Fresno Major Street Impact (FMSI) Fees:** This entitlement is in the **New Growth Area**; therefore pay all applicable growth area fees and citywide regional street impact fees. / Contact the Public Works Department, Frank Saburit at (559) 621-8797.

**Regional Transportation Mitigation Fee (RTMF):** Pay all applicable RTMF fees to the Joint Powers Agency located at 2035 Tulare Street, Suite 201, Fresno, CA 93721; (559) 233-4148 ext. 200; [www.fresnocog.org](http://www.fresnocog.org). Provide proof of payment or exemption **prior** to issuance of certificate of occupancy.

**In order to obtain street or building permit approval from the Public Works Department, an approval stamp with a signature from Land Planning Section is required on the site plan and inserted in the building sets.**

Questions relative to these conditions may be directed to Rogelio Ruiz (559) 621-8690 [Rogelio.Ruiz@fresno.gov](mailto:Rogelio.Ruiz@fresno.gov) in the Public Works Department, Land Planning Section.







2600 Fresno Street  
Fresno, California 93721-3604

Fire Department Comments:

Nicole Vasconcellos

10/19/2023

This project was reviewed by the Fire Department only for requirements related to water supply, fire hydrants, and fire apparatus access to the building(s) on site. Review for compliance with fire and life safety requirements for the building interior and its intended use are reviewed by both the Fire Department and the Building and Safety Section of DARM when a submittal for building plan review is made as required by the California Building Code by the architect or engineer of record for the building.

- 1) It appears that all lanes throughout shall be marked as fire lanes (curbs up to 28 feet shall be marked); show fire lanes throughout on the plan.

2600 Fresno Street  
Fresno, California 93721-3604

Fresno County Environmental Health:

Public Health

09/01/2023

Recommended Conditions of Approval:

- Construction permits for the proposed development should be subject to assurance of sewer capacity of the Regional Wastewater Treatment Facility. Concurrence should be obtained from the California Regional Water Quality Control Board (RWQCB). For more information, contact staff at (559) 445-5116.
- Construction permits for the proposed development should be subject to assurance that the City of Fresno community water system has the capacity and quality to serve this project. Concurrence should be obtained from the State Water Resources Control Board, Division of Drinking Water-Southern Branch. For more information call (559) 447-3300.
- The proposed project has the potential to expose nearby residents to elevated noise levels. Consideration should be given to the City of Fresno Municipal Code.
- Facilities that use and/or store hazardous materials and/or hazardous wastes shall meet the requirements set forth in the California Health and Safety Code (HSC), Division 20, Chapter 6.95, and the California Code of Regulations (CCR), Title 22, Division 4.5. Your proposed business will handle hazardous materials and/or hazardous waste and will be required to submit a Hazardous Materials Business Plan pursuant to the HSC, Division 20, Chapter 6.95 (<http://cers.calepa.ca.gov/>). Contact the Fresno County Hazmat Compliance Program at (559) 600-3271 for more information.
- As a measure to protect ground water, all water wells and/or septic systems that exist or have been abandoned within the project area should be properly destroyed by an appropriately licensed contractor.
- Should any underground storage tank(s) be found during the project, the applicant shall apply for and secure an Underground Storage Tank Removal Permit from the Fresno County Department of Public Health, Environmental Health Division. Contact the Fresno County Hazmat Compliance Program at (559) 600-3271 for more information.





## DEPARTMENT OF PUBLIC UTILITIES

### MEMORANDUM

**DATE:** April 19, 2024

**TO:** JOHN GEORGE – Planner III  
Planning & Development Department – Current Planning

**FROM:** DEJAN PAVIC, PE, Projects Administrator  
Department of Public Utilities – Utilities Planning & Engineering

**SUBJECT: DPU CONDITIONS OF APPROVAL FOR P23-01190 114-UNIT MULTI-FAMILY RESIDENTIAL COMPLEX – APNs 579-220-33, 49, & 71**

#### **General Requirements**

1. Engineered improvement plans, prepared by a Registered Civil Engineer, if necessary, shall be submitted for Department of Public Utilities review and approval.
2. All Department of Public Utilities facilities shall be constructed in accordance with The Department of Public Works standards, specifications, and policies.
3. Street easements and/or deeds shall be recorded prior to approval of improvement plans.
4. A street work permit is required for any work in the Right-of-Way.
5. All underground utilities shall be installed prior to permanent street paving.

#### **Water Service Requirements**

The nearest water mains to serve the Project are a 12-inch water main located in East Copper River Avenue and a 12-inch water main located in North Maple Avenue. Water facilities are available to provide service to the Project subject to the following requirements:

1. On-site water facilities shall be private.
2. Installation of a new water service(s) and meter(s) shall be required.
3. The applicant shall be financially responsible for the abandonment of any unused water services previously installed to the property.
4. Two independent sources of water, meeting Federal and State Drinking Water Act Standards, are required to serve the tract including any subsequent phases thereof. The two-source requirement may be accomplished through any combination of

DPU CONDITIONS OF APPROVAL FOR P23-01190 114-UNIT MULTI-FAMILY  
RESIDENTIAL COMPLEX – APNs 579-220-33S, 49S & 71S

April 19, 2024

Page 2 of 4

water main extensions, construction of supply wells, or other acceptable sources of water supply approved by the Department of Public Utilities Director or designee.

5. Destroy any existing on-site well(s) in compliance with the State of California Well Standards, Bulletins 74-81 and 74-90, or current revisions, issued by California Department of Water Resources, Fresno County standards, and City of Fresno standards. Applicant shall comply with Fresno Municipal Code (FMC) Section 6-518, as may be amended from time to time.

### **Water Supply Requirements**

1. The applicant shall be required to pay Water Capacity Fee charges for the installation of new water services and meters to serve the Project.
  - a. The Water Capacity Fee charge assessed to the applicant shall be based on the number and size of service connections and water meters required to serve the Project.
  - b. The Water Capacity Fee charges by meter size are defined in the City's Master Fee Schedule (MFS).
  - c. In lieu of the foregoing Water Supply Requirements described in Subparagraphs 1.a. and 1.b., the applicant/developer may submit/use available Project Water EDUs (credits), if any, in accordance with the Copper River Ranch Water Supply Implementation Agreement dated November 17, 2016, as amended.
  - d. The City reserves the right to require an applicant to increase or decrease the size of a water meter for the Project to ensure that it is properly sized to accommodate fire protection requirements, and to allow for accurate volumetric flow measurements at low- and high-flow conditions.
  - e. The Water Capacity Fee Charge for any new or expanded service connection shall be payable prior to the issuance of a building permit at the fee level in effect on the date such permit is issued.
2. The applicant shall be required to pay all other water-related fees and charges in accordance with the City's MFS and FMC.

### **Sewer Requirements**

The nearest sanitary sewer mains to serve the Project are a 12-inch sewer main located in East Copper River Avenue and a 24-inch sewer main located in the public utility easement located along the westerly property line of the Project. Sanitary sewer facilities are available to provide service to the Project subject to the following requirements:

1. Installation of new sewer service branch(es) shall be required.

DPU CONDITIONS OF APPROVAL FOR P23-01190 114-UNIT MULTI-FAMILY  
RESIDENTIAL COMPLEX – APNs 579-220-33S, 49S & 71S

April 19, 2024

Page 3 of 4

2. On-site sanitary sewer facilities shall be private.
3. All existing on-site private septic systems (including septic tanks) shall be destroyed and abandoned in compliance with the State of California standards, Fresno County standards, and City of Fresno standards, as may be amended from time to time. All sewer connections and sewer main extensions shall comply with FMC Section 6-303(a), as may be amended from time to time.
4. The applicant shall be financially responsible for abandonment of any unused sewer services previously installed to the property.

**Sanitary Sewer Fees**

The following Sewer Connection Charges are due and shall be paid for the Project:

1. Lateral Sewer Charge.
2. Oversize Sewer Charge.
3. Wastewater Facility Sewer Charge (Multi-family Residential).
4. Copper Avenue Sewer Lift-Station Benefit Service Area Fee.
5. Upon connection of this Project to the City Sewer System the owner shall be subject to payment of Sewer Facility Charges per FMC Sections 6-304 and 6-305. Sewer Facility Charges consist of two components: a Wastewater Facilities Charge and Trunk Sewer Charge, where applicable.
6. Sewer Facility Charges are collected after occupancy on a monthly basis, based on metered usage (water or sewer effluent). The applicant may contact the Department of Public Utilities/Wastewater-Environmental Control at (559) 621-5153 to receive an estimated cost of the Sewer Facility Charges applicable to the Project (based on a constant sewer discharge and loading (Biochemical Oxygen Demand [BOD] and Total Suspended Solids [TSS] levels anticipated) at the current rates in effect at that time, per City of Fresno MFS. The applicant shall provide data regarding estimated sewer discharge rates (flow) and loading (BOD/TSS levels) required for calculating the estimated charges.

**Solid Waste Requirements**

For the purpose of establishing City solid waste service policies, multi-family complexes are defined as complexes composed of three (3) dwelling units or more per parcel. These service requirements apply to all multi-family complexes within the City of Fresno.

1. This location is serviced by a Commercial Solid Waste Franchisee. For service information, please contact Allied Waste at (559) 275-1551 or (800)-493-4285.



DPU CONDITIONS OF APPROVAL FOR P23-01190 114-UNIT MULTI-FAMILY  
RESIDENTIAL COMPLEX – APNs 579-220-33S, 49S & 71S

April 19, 2024

Page 4 of 4

2. All trash bins provided to multi-family complexes must be serviced with a frequency of at least twice per week. This standard does not apply to frequency of service for recycling bins.
3. All multi-family complexes are required to subscribe for recycling services, per FMC 9-405.1. Recycling services may be provided by the City of Fresno or any private recycling service provider. Recycling services must include, at the minimum, cardboard, newspaper, paper, glass, plastics, beverage containers, and metal recycling.
4. All trash and recyclable material must be placed in approved containers, per FMC 9-404. At no time may trash and recyclable material be placed on the ground or pavement.

**Note 1:** a part of these Solid Waste Requirements (i.e. adding a third/forth compartment in the trash enclosure to accommodate a bin for green and/or organic/food waste) will be needed to comply with SB 1383, as mandated by the State of California. Refer to Public Works Standard Specification for 3-cell enclosure details.

5. Bin enclosures, if provided on site, must be used exclusively for the storage of trash and recycling bins, per The Public Works Standard Specifications P-33 and P-34.
6. All Solid Waste and Recycling services collectively must equal or exceed a 2:1 ratio of 2 units per one cubic yard of service per week. This minimum service applies to all multi-family complexes (i.e., 24-unit complex must have a minimum of 12 cubic yards of solid waste and recycling service per week).
7. Service Route Permits and Location Permits are required for all private trash company services within the City of Fresno per FMC 9-408. All private company trash service arrangements must be pre-approved through Solid Waste Management Division.
8. Dimension offset of proposed trash enclosure from property line. The safe back up limit per a solid waste vehicle shall not exceed 45-feet.
9. Americans with Disability Act (ADA) requirement for multi-family residential developments:

The applicant shall install (construct) a trash enclosure(s) for the Project that complies with the City's ADA requirements as defined in the City's Standard Drawings, Details and Specifications. The certificate of occupancy for the Project shall be withheld until the applicant installs (constructs) the trash enclosure(s) in accordance with the City's ADA requirements.



August 17, 2023

John George  
DARM – Development Services Division  
2600 Fresno Street  
Fresno, CA 93721

SUBJECT: P23-01190  
T-6439; 114 multi-family units  
2.57 acres at the southwest corner of E Copper River Dr and N Maple Ave  
APN: 579-220-49S

Dear John George:

The purpose of this letter is to provide school district information relative to the above-referenced development and to comply with Business and Professions Code section 11010, subdivision (b)(11)(A) regarding the provision of school-related information to the developer/owner and the State Department of Real Estate.

1. Elementary School Information:

- (a) The subject land is presently within the attendance area of the elementary school (grades K-6) listed below:

School Name: *Fugman Elementary*  
Address: *10825 N Cedar Ave Fresno CA 93730-3586*  
Telephone: *(559) 327-8700*  
Capacity: *875*  
Enrollment: *808 (CBEDS enrollment 2022-23 school year)*

- (b) Because of projected growth in the District and the District's plans for construction of new school facilities, it is possible that (1) adjustment of school attendance areas could occur in the future such that students residing in the project area may be required to attend an elementary school other than the school listed above, and (2) students residing in the project area may attend more than one elementary school within the District during their elementary school years.

**Governing Board**

Hugh Awtrey  
Deena L. Combs-Flores  
David DeFrank  
Steven G. Fogg, M.D.  
Yolanda Moore  
Clinton Olivier  
Tiffany Stoker Madsen

**Administration**

Corrine Folmer, Ed.D.  
*Superintendent*

Norm Anderson  
*Deputy Superintendent*

Marc Hammack, Ed.D.  
*Associate Superintendent*

Barry S. Jager, Jr.  
*Associate Superintendent*

Michael Johnston  
*Associate Superintendent*

2. Intermediate School Information:

School Name: *Granite Ridge Intermediate*  
Address: *2770 E International Ave Fresno CA 93730-5400*  
Telephone: *(559) 327-5000*  
Capacity: *1512*  
Enrollment: *1118 (CBEDS enrollment 2022-23 school year)*

3. High School Information:

School Name: *Clovis North High School*  
Address: *2770 E International Ave Fresno CA 93730-5400*  
Telephone: *(559) 327-5000*  
Capacity: *2700*  
Enrollment: *2389 (CBEDS enrollment 2022-23 school year)*

4. Bus transportation is currently provided for grades K-6 students residing further than one mile from school and for grades 7-12 students residing further than two and one-half miles from school. Transportation will be available for students attending the above-identified elementary, intermediate and high schools in accordance with District standards in effect at the time of enrollment.
5. The District currently levies a school facilities fee of \$5.68 per square foot (as of July 3, 2023) for residential development. The fee is adjusted periodically in accordance with law. New development on the subject property will be subject to the fee in place at the time fee certificates are obtained.

The District hereby requests that the information in this letter be provided by the owner/subdivider to all prospective purchasers of property within the project.

Thank you for the opportunity to comment on the project. Please contact me if you have any questions regarding this letter.

Sincerely,



Michael Johnston  
Associate Superintendent  
Administrative Services





2907 S. Maple Avenue  
Fresno, California 93725-2208  
Telephone: (559) 233-7161  
Fax: (559) 233-8227

**CONVEYANCE. COMMITMENT. CUSTOMER SERVICE.**

September 14, 2023

John George  
Development and Resource Management  
City of Fresno  
2600 Fresno Street, Third Floor  
Fresno, CA 93721

RE: Development Permit Application P23-01190  
N/W Copper and Maple avenues

Dear Mr. George:

The Fresno Irrigation District (FID) has reviewed the Development Permit Application P23-01190 for which the applicant proposes the construction of a 114-unit multi-family residential complex, APNs: 579-220-33, 49, 71 . FID has the following comments:

1. FID does not own, operate or maintain any facilities located on the subject property as shown on the attached FID exhibit map. The subject property is located approximately 4,100 feet outside the FID boundary.
2. The proposed development appears to be within the City of Fresno but lies outside FID's boundary line. The development is not entitled to water from the Kings River.
3. FID is concerned that the proposed development may negatively impact local groundwater supplies including those areas adjacent to or neighboring the proposed development area. The area was historically open land with minimal to no water use. Under current circumstances the project area is experiencing a modest but continuing groundwater overdraft. Should the proposed development result in a significant increase in dependence on groundwater, this deficit will increase. FID recommends the City of Fresno require the proposed development balance anticipated groundwater use with sufficient recharge of imported surface water in order to preclude increasing the area's existing groundwater overdraft problem.
4. It is unclear if the source of water for this development is solely groundwater or a mixture of treated surface water. If treated surface water will be used, the City must use its Friant supply or acquire additional water from a water purveyor, such as FID for that purpose, so as to not reduce water supplies to or create water supply deficits in other areas of the City. Water supply issues must be resolved before any further "hardening" of the water supply demand is allowed to take place.

5. The City of Fresno and FID have been working to address water supplies issues for development outside of the FID service area. We encourage the City to continue towards finding solutions to minimize the impacts of changes in land uses and to mitigate any existing adverse water supply impacts within the development a California enacted landmark legislation in 2014 known as the Sustainable Groundwater Management Act (SGMA). The act requires the formation of local groundwater sustainability agencies (GSAs) that must assess conditions in their local water basins and adopt locally-based management plans. FID and the City of Fresno are members of the North Kings Groundwater Sustainability Agency which will manage the groundwater basin within the FID service area. This area is completely reliant on groundwater pumping and SGMA will impact all users of groundwater and those who rely on it. The City of Fresno should consider the impacts of the development on the City's ability to comply with requirements of SGMA.

Thank you for submitting the proposed project for our review. We appreciate the opportunity to review and comment on the subject documents for this project. If you have any questions, please feel free to contact Chris Lundeen at (559) 233-7161 extension 7410 or [clundeen@fresnoirrigation.com](mailto:clundeen@fresnoirrigation.com).


Sincerely,



Laurence Kimura, P.E.  
Chief Engineer

Attachment






FRESNO IRRIGATION DISTRICT

**Legend**

- FID Canal
- Private Canal
- Abandoned Canal
- Stream Group
- Other-Creek/River
- Other-Pipeline
- FID Pipeline
- Private Pipeline
- Abandoned Pipeline
- FID Boundary
- Railroad
- Streets & Hwys
- Parcel
- FIMFCD Acquired Basins
- FIMFCD Proposed Basins

This map was produced by the Fresno Irrigation District and is provided for reference and informational purposes only and is not intended to show map scale accuracy or all inclusive map features, nor for legal purposes. FID makes no statements regarding the accuracy of this map as the features shown are in their approximate location. Please contact the FID Engineering Dept. at (559) 233-7161 for further information on FID facilities.

Path: G:\Figures\20230727 FID Compact.mxd  
 Spatial Reference  
 Name: NAD 1983 StatePlane California IV FIPS 9404



Subject Property  
 APNs: 579-220-33, 49, 71

Approx. 4,100ft

FID Boundary

San Joaquin  
 River No. 902

ALCANTATE

AUBERRY

CEDAR

COPPER RIVER

COPPER

WILLOW

MILLBROOK

MAPLE

INTERNATIONAL

Enterprise No. 109

Booster Pump  
 No. 117

FORT WASHINGTON

BEHYMER

Los Almos No.  
 375 (Pvt.)

Woodward No. 377

Ambrosia No.  
 373 (Pvt.)

Maplin  
 No. 118

WOODWARD

CHESTNUT

PHILLIPS

PHILLIPS No.  
 158 (Pvt.)

WILLOW

WILLOW

WOODWARD No. 377  
 MINNEWAWA



FRESNO METROPOLITAN FLOOD CONTROL DISTRICT  
NOTICE OF REQUIREMENTS

**PUBLIC AGENCY**

JOHN GEORGE  
PLANNING & DEVELOPMENT DEPARTMENT  
CITY OF FRESNO  
2600 FRESNO STREET  
FRESNO, CA 93721-3604

**DEVELOPER**

DREW PHELPS, GRANVILLE HOMES  
396 W. HERNDON AVE., STE. 101  
FRESNO, CA 93711

PROJECT NO: **2023-01190**

ADDRESS: **1911 E. COPPER RIVER DR.**

APN: **579-220-33S, 49S, 579-220-71S**

SENT: **October 04, 2023**

Drainage Area(s)	Preliminary Fee(s)	Development Review Service Charge(s)	Fee(s)	
DE	\$67,638.00	NOR Review	\$251.00	To be paid prior to release of District comments to Public Agency and Developer.
		Grading Plan Review	\$1,274.00	Amount to be submitted with first grading plan submittal.
<b>Total Drainage Fee: \$67,638.00</b>		<b>Total Service Charge: \$1,525.00</b>		

The proposed development will generate storm runoff which produces potentially significant environmental impacts and which must be properly discharged and mitigated pursuant to the California Environmental Quality Act and the National Environmental Policy Act. The District in cooperation with the City and County has developed and adopted the Storm Drainage and Flood Control Master Plan. Compliance with and implementation of this Master Plan by this development project will satisfy the drainage related CEQA/NEPA impact of the project mitigation requirements.

Pursuant to the District’s Development Review Fee Policy, the subject project shall pay review fees for issuance of this Notice of Requirements (NOR) and any plan submittals requiring the District’s reviews. The NOR fee shall be paid to the District by Developer before the Notice of Requirement will be submitted to the City. The Grading Plan fee shall be paid upon first submittal. The Storm Drain Plan fee shall be paid prior to return/pick up of first submittal.

The proposed development shall pay drainage fees pursuant to the Drainage Fee Ordinance prior to issuance of a building permit at the rates in effect at the time of such issuance. The fee indicated above is valid through 3/07/24 based on the site plan submitted to the District on 8/16/23 Contact FMFCD for a revised fee in cases where changes are made in the proposed site plan which materially alter the proposed impervious area.

Considerations which may affect the fee obligation(s) or the timing or form of fee payment:

- a.) Fees related to undeveloped or phased portions of the project may be deferrable.
- b.) Fees may be calculated based on the actual percentage of runoff if different than that typical for the zone district under which the development is being undertaken and if permanent provisions are made to assure that the site remains in that configuration.
- c.) Creditable storm drainage facilities may be constructed, or required to be constructed in lieu of paying fees.
- d.) The actual cost incurred in constructing Creditable drainage system facilities is credited against the drainage fee obligation.
- e.) When the actual costs incurred in constructing Creditable facilities exceeds the drainage fee obligation, reimbursement will be made for the excess costs from future fees collected by the District from other development.
- f.) Any request for a drainage fee refund requires the entitlement cancellation and a written request addressed to the General Manager of the District within 60 days from payment of the fee. A non refundable \$300 Administration fee or 5% of the refund whichever is less will be retained without fee credit.

**FR  
DPA  
No. 2023-01190**

FRESNO METROPOLITAN FLOOD CONTROL DISTRICT  
NOTICE OF REQUIREMENTS

Page 2 of 3

FR DPA No. 2023-01190

Approval of this development shall be conditioned upon compliance with these District Requirements.

1.  a. Drainage from the site shall  
 b. Grading and drainage patterns shall be as identified on Exhibit No. 1.  
 c. The grading and drainage patterns shown on the site plan conform to the adopted Storm Drainage and Flood Control Master Plan.
  
2. The proposed development shall construct and/or dedicate Storm Drainage and Flood Control Master Plan facilities located within the development or necessitated by any off-site improvements required by the approving agency:  
 Developer shall construct facilities as shown on Exhibit No. 1 as  
 None required.
  
3. The following final improvement plans and information shall be submitted to the District for review prior to final development approval:  
 Grading Plan  
 Street Plan  
 Storm Drain Plan  
 Water & Sewer Plan  
 Final Map  
 Drainage Report (to be submitted with tentative map)  
 Other  
 None Required
  
4. Availability of drainage facilities:  
 a. Permanent drainage service is available provided the developer can verify to the satisfaction of the City that runoff can be safely conveyed to the Master Plan inlet(s).  
 b. The construction of facilities required by Paragraph No. 2 hereof will provide permanent drainage service.  
 c. Permanent drainage service will not be available. The District recommends temporary facilities until permanent service is available.  
 d. See Exhibit No. 2.
  
5. The proposed development:  
 Appears to be located within a 100 year flood prone area as designated on the latest Flood Insurance Rate Maps available to the District, necessitating appropriate floodplain management action. (See attached Floodplain Policy.)  
 Does not appear to be located within a flood prone area.
  
6.  The subject site contains a portion of a canal or pipeline that is used to manage recharge, storm water, and/or flood flows. The existing capacity must be preserved as part of site development. Additionally, site development may not interfere with the ability to operate and maintain the canal or pipeline.

FRESNO METROPOLITAN FLOOD CONTROL DISTRICT  
NOTICE OF REQUIREMENTS

Page 3 of 3

FR  
DPA  
No. 2023-01190

7. The Federal Clean Water Act and the State General Permits for Storm Water Discharges Associated with Construction and Industrial Activities (State General Permits) require developers of construction projects disturbing one or more acres, and discharges associated with industrial activity not otherwise exempt from National Pollutant Discharge Elimination System (NPDES) permitting, to implement controls to reduce pollutants, prohibit the discharge of waters other than storm water to the municipal storm drain system, and meet water quality standards. These requirements apply both to pollutants generated during construction, and to those which may be generated by operations at the development after construction.
- a. State General Permit for Storm Water Discharges Associated with Construction Activities, effective July 1, 2010, as amended. A State General Construction Permit is required for all clearing, grading, and disturbances to the ground that result in soil disturbance of at least one acre (or less than one acre) if part of a larger common plan of development or sale). Permittees are required to: submit a Notice of Intent and Permit Registration Documents to be covered and must pay a permit fee to the State Water Resources Control Board (State Board), develop and implement a storm water pollution prevention plan, eliminate non-storm water discharges, conduct routine site inspections, train employees in permit compliance, and complete an annual certification of compliance.
  - b. State General Permit for Storm Water Discharges Associated with Industrial Activities, April, 2014 (available at the District Office). A State General Industrial Permit is required for specific types of industries described in the NPDES regulations or by Standard Industrial Classification (SIC) code. The following categories of industries are generally required to secure an industrial permit: manufacturing; trucking; recycling; and waste and hazardous waste management. Specific exemptions exist for manufacturing activities which occur entirely indoors. Permittees are required to: submit a Notice of Intent to be covered and must pay a permit fee to the State Water Resources Control Board, develop and implement a storm water pollution prevention plan, eliminate non-storm water discharges, conduct routine site inspections, train employees in permit compliance, sample storm water runoff and test it for pollutant indicators, and annually submit a report to the State Board.
  - c. The proposed development is encouraged to select and implement storm water quality controls recommended in the Fresno-Clovis Storm Water Quality Management Construction and Post-Construction Guidelines (available at the District Office) to meet the requirements of the State General Permits, eliminate the potential for non-storm water to enter the municipal storm drain system, and where possible minimize contact with materials which may contaminate storm water runoff.
8. A requirement of the District may be appealed by filing a written notice of appeal with the Secretary of the District within ten days of the date of this Notice of Requirements.
9. The District reserves the right to modify, reduce or add to these requirements, or revise fees, as necessary to accommodate changes made in the proposed development by the developer or requirements made by other agencies.
10. X See Exhibit No. 2 for additional comments, recommendations and requirements.



Debbie Campbell  
Design Engineer, RCE

Digitally signed by Debbie Campbell Date: 10/4/2023 10:17:09 AM



Anthony Zaragoza  
Engineer III

Digitally signed by Anthony Zaragoza Date: 9/11/2023 4:29:05 PM

CC:


DA REAL ESTATE HOLDINGS LLC

1396 W. HERNDON AVE., #101







FRESNO, CA 93711



NOTE: THIS MAP IS SCHEMATIC. DISTANCES, AMOUNT OF CREDITABLE FACILITIES, AND LOCATION OF INLET BOUNDARIES ARE APPROXIMATE.



## LEGEND

-  Existing Master Plan Facilities
-  Private Facilities
-  Direction Of Drainage
-  Existing FID Facilities
-  Inlet Boundary
-  Limits Of FR DPA 2023-01190



1" = 300'

**FR DPA 2023-01190**  
**DRAINAGE AREA "DE"**

### EXHIBIT NO. 1

## FRESNO METROPOLITAN FLOOD CONTROL DISTRICT



## **OTHER REQUIREMENTS**

### **EXHIBIT NO. 2**

No surface runoff shall be directed towards the District basin. The District requests that the grading Engineer contact the District as early as possible to review the proposed site grading for verification and acceptance of grades at our mutual property line prior to preparing a grading plan.

The District recommends a single fence between the site and the District's basin. The developer should contact the District so that alternatives to a dual fence can be reviewed. If a fence other than the existing chain link fence is proposed, District review and approval of the proposed fence is required.

A private storm drain system currently exists within the area of the proposed project, as shown on Exhibit No. 1. The private system connects to the District's existing Master Plan facilities. The developer of FR DPA 2023-01190 shall relocate and/or remove the private system as required to avoid the proposed project or the developer will be required to sign a Release of Liability Agreement with the District.

Permanent drainage service is available provided the developer can verify to the satisfaction of the District that runoff can be safely conveyed to the private facilities, as shown on Exhibit No. 1.

The City shall verify that drainage covenants are in place, as necessary, to allow surface runoff to reach the private facilities.

In an effort to improve storm runoff quality, outdoor storage areas shall be constructed and maintained such that material that may generate contaminants will be prevented from contact with rainfall and runoff and thereby prevent the conveyance of contaminants in runoff into the storm drain system.

The District encourages, but does not require that roof drains from non-residential development be constructed such that they are directed onto and through a landscaped grassy swale area to filter out pollutants from roof runoff.

Runoff from areas where industrial activities, product, or merchandise come into contact with and may contaminate storm water must be treated before discharging it off-site or into a storm drain. Roofs covering such areas are recommended. Cleaning of such areas by sweeping instead of washing is to be required unless such wash water can be directed to the sanitary sewer system. Storm drains receiving untreated runoff from such areas shall not be connected to the District's system. Loading docks, depressed areas, and areas servicing or fueling vehicles are specifically subject to these requirements. The District's policy governing said industrial site NPDES program requirements is available on the District's website at: [www.fresnofloodcontrol.org](http://www.fresnofloodcontrol.org) or contact the District's Environmental Department for further information regarding these policies related to industrial site requirements.

# CITY OF FRESNO

## DEVELOPMENT AND IMPACT FEE ESTIMATE

The following estimates are based on preliminary conceptual information. The exact fee obligation will be computed at the time of development by Public Works Department, Land Division & Engineering. The fee rates in effect at the time of building permit issuance, as determined by the Master Fee Schedule, shall apply.

**Proposed Development:** Copper-Maple Multi-Family - 1911 E. Copper River Drive

**A.P.N.** 579-220-33S, 49S, 71S

**Planned Land Use:** Residential - Urban Neighborhood

**Current Zoning:** RM-2/UGM/cz

**Site Area:** +/- 7.16 acres

**Living Units / LUE:** 114 Living Units

**Entitlement:** P23-01190

**Estimate Date:** August 28, 2023

WATER CONNECTION CHARGES	Service Area	Quantity	Units	Fee Rate	Amount Due	Notes
	Irrigation Service & Meter Charge	2"	1	EA.	\$2,671.00	\$2,671.00
Time & Materials Charge	6" FM	1	EA.	\$24,100.00	\$24,100.00	[1] [6]
Frontage Charge		0	L.F.	\$6.50	<i>satisfied w/ const.</i>	
Water Capacity Fee	6"	1.00	EA.	\$72,314.65	\$72,314.65	[1] [6]

<b>Total Water Connection Charges</b>	<b>\$99,085.65</b>	<b>[1]</b>
---------------------------------------	--------------------	------------

SEWER CONNECTION CHARGES	Service Area	Quantity	Units	Fee Rate	Amount Due	Notes
	House Branch Sewer Charge		[2]	EA	\$0.00	[2]
Lateral Sewer Charge		0	Sq.Ft.	\$0.10	<i>satisfied w/ const.</i>	
Oversized Sewer Charge		0	Sq.Ft.	\$0.05	<i>satisfied w/ const.</i>	
Copper Avenue Sewer Lift Station Benefit Service Area Charge		114	Units	\$71.70	\$8,173.80	[6]
Wastewater Facilities Charge		114	Units	\$566.80	\$64,615.20	[6]
Trunk Sewer Charge		114	Units	\$6.89	\$785.46	[6]

<b>Total Sewer Connection Charges</b>	<b>\$73,574.46</b>	<b>[3]</b>
---------------------------------------	--------------------	------------

CITYWIDE/REGIONAL IMPACT FEES	Service Area	Quantity	Units	Fee Rate	Amount Due	Notes
	Citywide Fire Facilities Impact Fee	Multi-Family	114	Units	\$1,774.37	\$202,278.18
Citywide Park Facility Impact Fee	Multi-Family	114	Units	\$3,921.33	\$447,031.62	[7] [9]
Citywide Police Facilities Impact Fee	Multi-Family	114	Units	\$736.01	\$83,905.14	[7]
Citywide Regional Street Charge	Multi-Family	7.16	AC	\$17,360.97	\$124,304.55	[6]
New Growth Area Major Street Charge	Multi-Family	7.16	AC	\$54,385.63	\$389,401.11	[6]
Traffic Signal Mitigation Impact Fee	Multi-Family	114	Units	\$601.64	\$68,586.96	[6]

<b>Total Citywide/Regional Impact Fees</b>	<b>\$1,315,507.56</b>
--	-----------------------

COPPER RIVER RANCH IMPACT FEES	Service Area	Quantity	Units	Fee Rate	Amount Due	Notes
	Interior Collector Impact Fee	CRR	7.16	AC	\$31,155.00	\$223,069.80
Associated Major Roadway Facility Fee	CRR	7.16	AC	\$4,836.00	\$34,625.76	[6] [8]
Sewer Backbone System Facility Fee	CRR	114	Units	\$479.00	\$54,606.00	[6] [8]
Friant Widening Mitigation Fee	CRR	835	ADT's [8]	\$9.76	\$8,149.60	[6]
Clovis Mitigation Fee	CRR	835	ADT's [8]	\$38.99	\$32,556.65	[6]

<b>Total Copper River Ranch Impact Fees</b>	<b>\$353,007.81</b>
---	---------------------

<b>Total Fees and Charges</b>	<b>\$1,841,175.48</b>
-------------------------------	-----------------------



# CITY OF FRESNO

## DEVELOPMENT AND IMPACT FEE ESTIMATE

### **NOTES:**

Within the City of Fresno's sphere of influence there are other sewer and water utility providers. If the project is within one of those districts, the developer must provide confirmation from the representative Districts that all conditions for sewer and/or water connections and services have been satisfied, prior to issuance of a Building Permit.

**Outside agencies developer impact fees:** It is the developer's responsibility to contact those agencies for their fee estimates. These agencies include but are not limited to; Fresno County, Council of Fresno County Governments (FCOG), Fresno Metropolitan Flood Control District (FMFCD), various School Districts that serve the City of Fresno, etc.

**NOTICE OF 90-DAY PROTEST PERIOD** (GOVERNMENT CODE §66020(d)(1))

*A protest filed pursuant to subdivision and/or development (a) shall be filed at the time of approval or conditional approval of the development or within 90 days after the date of the imposition of the fees, dedications, reservations, or other exactions to be imposed on a development project. Each local agency shall provide to the project applicant a notice in writing at the time of the approval of the project or at the time of the imposition of the fees, dedications, reservations, or other exactions, a statement of the amount of the fees or a description of the dedications, reservations, or other exactions, and notification that the 90-day approval period in which the applicant may protest has begun.*

- The Board of Directors of the Fresno County Regional Transportation Mitigation Fee Agency approved Resolution No. 2009-01 requiring the payment of Regional Transportation Mitigation Fee. The effective date of this resolution is January 1, 2010. Please contact the Council of Fresno County Governments (FCOG) at (559) 233-4148 to determine this fee obligation. Confirmation by the FCOG is required before the City of Fresno can issue the Certificate of Occupancy.
- On December 8, 2016, Fresno City Council adopted Resolution No. 2016-258, effective July 1, 2018, administratively updating the impact fees adjusted by this resolution annually to the percentage change in the 20-City Construction Cost Index as reported in the Engineering News Record (ENR) for the 12-month period ending of May of the year of adjustment.
- Payment of Fresno Metropolitan Flood Control District (FMFCD) impact fees may be required. Please contact FMFCD at (559) 456-3292 to determine fee obligation.
- Payment of applicable school district fees is required prior to issuance of Building Permit. Please contact the respective school district to satisfy your fee obligation. Confirmation by the respective school district is required before the City of Fresno can issue building permits

**[1] Fees for Water Service Connections and/or Meters, and Water Capacity due at time of development. Charges based on service and/or meter sizes, (Rates as established by the Master Fee Schedule), determined by the Developer.**

**[2] Sewer House branches to be installed by Developer at the Developer's cost.**

**[3] Upon occupancy of the project, the subdivider shall pay the appropriate sewer facility charge pursuant to the Simple Tiered Equity Program (STEP) as determined by the City of Fresno Department of Finance, Utilities Billing & Collection Division (559-621-6765).**

**[4] The Wastewater Facilities Charge (WWFC) is applicable to single family, duplex, and triplex developments. (FMC 6-302(i)); For Condominium conversions, WWFC may stay in the S.T.E.P. if the project continues to be master metered for water. If the condominiums are individually metered, the developer will pay the pro-rated portion of these fees.**

**[5] The Trunk Sewer Charge is applicable to single family, duplex, and triplex developments. (FMC 6-302(i)); For Condominium conversions, Trunk Sewer Charges may stay in the S.T.E.P. if the project continues to be master metered for water. If the condominiums are individually metered, the developer will pay the pro-rated portion of these fees.**

**[6] Due at Building Permit**

**[7] Due with Certificate of Occupancy**

**[8] Construction Fee Credits may be applicable. Contact the Public Works Engineering Services Division at (559) 621-8685 for more information.**

**[9] Parks fee applicable only to residential developments**

**[10] Fee not applicable on replacement or reconstruction of an existing structure that has been destroyed or demolished provided that the Building Permit for new construction is obtained within one year after the building is destroyed or demolished, and there is no change in the land use designation. (Res. Nos. 2005-428, 429)**

**[11] Subject to the acceptance date of the vesting tentative map, fee may not be applicable until 2-years after the date of Final Map recordation; when applicable, fee is due at Building Permit for all un-developed lots at the fee rate then in effect.**

**Prepared and Reviewed By: Frank Saburit**

**Date:**

**(559) 621-8797**

**City of Fresno Public Works Department  
Land Division & Engineering**

2600 Fresno Street  
Fresno, California 93721-3604

**Building and Safety Comments:**

Christina Mendez

08/28/2023

The following items require a separate process with additional fees and timelines, in addition to the Development Permit Application process.

-

1. Building, Grading and Utility plans are required to be submitted to Building and Safety Services Division for approval and permits for the proposed project.

- Verify permanent drainage facilities are provided by Fresno Metropolitan Flood Control District (FMFCD). Contact Jason Clark at (559) 456-3292 for additional information.

- All Construction Documents must be designed, stamped and signed by a licensed Architect/Engineer.

- Bicycle parking shall be provided per California Green Building Standards Code (CGBSC) 5.106.4.1.1 & 5.106.4.1.2.

- Electric Vehicle Charging shall be provided per California Green Building Standards Code (CGBSC) 4.106.4.

- Fire-rated assemblies with limited opening may be required between the proposed buildings. Refer to CBC Table 705.5 and Table 705.8 for additional information and requirements.

- Clarify on the cover sheet of the construction documents if this will be privately funded or publicly funded project/facility.

- i. Privately funded Multi-family Residential projects need to meet all requirements of CBC chapter 11A.

- ii. Publicly funded Multi-family Residential projects need to meet all requirements of CBC chapter 11B.



September 5, 2023

Re: P23-01190 Copper Maple Multifamily (Copper River & Maple)  
1911 E Copper River Drive, Fresno, CA 93730

Dear City of Fresno:

Thank you for giving us the opportunity to review the subject plans. The proposed Copper Maple Multifamily development is within the same vicinity of PG&E's existing facilities that impact this property.

The Copper Maple Multifamily development proposes trees and landscaping within the existing ten foot (10') wide Public Utility Easement (P.U.E.) on the subject parcel. PG&E operates and maintains existing underground gas and electric distribution facilities within said P.U.E. All trees and brush installed within said P.U.E. must maintain a minimum five foot (5') horizontal clearance from all PG&E facilities within said P.U.E. Trees, brush, and landscaping with invasive roots can cause unintended damage to underground utility facilities and may result in a significant safety hazard.

The Copper Maple Multifamily development proposes a fence along, and to cross, said P.U.E. The proposed fence may only enter said P.U.E. to cross and may not be installed longitudinally within said P.U.E. No fence posts or footings may be installed over or between any PG&E facilities with said P.U.E. Any fence posts or footings installed within said P.U.E. must maintain a minimum of one foot (1') horizontal clearance from all PG&E facilities.

Please contact the Building and Renovation Center (BRSC) for facility map requests by calling 1-877-743-7782 and PG&E's Service Planning department at [www.pge.com/cco](http://www.pge.com/cco) for any modification or relocation requests, or for any additional services you may require.

As a reminder, before any digging or excavation occurs, please contact Underground Service Alert (USA) by dialing 811 a minimum of 2 working days prior to commencing any work. This free and independent service will ensure that all existing underground utilities are identified and marked on-site.

If you have any questions regarding our response, please contact me at [Justin.Newell@pge.com](mailto:Justin.Newell@pge.com).

Sincerely,

Justin Newell  
Land Management  
916-594-4068